


Scott Robertson

From: [REDACTED]
Sent: Tuesday, 20 August 2024 5:18 PM
To: Development
Cc: [REDACTED]
Subject: RE: MCUI/44/2024 - Request for Third Party Advice (Energex) - 283-293 Logan Reserve Road, Logan Reserve
Categories: Kerry

Hi,
Thankyou for seeking third party advice from Energex in relation to the development application over the above mentioned site. On behalf of Energex I have carried out an assessment of the proposal in relation to Energex's interests. There have been a number of issues recently in regards to development in this locality, particularly residential development in close proximity to the existing 110kv overhead line. However, in this instance, there are no concerns with the proposed Place of Worship and Community Use given that the buildings are located a significant distance (approx 20m) from the 110kv line, which runs along the eastern side of Logan Reserve Road (as seen in the aerial below). I note that the 110kv line on the western side is underground and doesn't pose the same clearance and EMF issues. As such, we have no comments regarding the subject application.



If you have any questions, please do not hesitate to contact myself.



unauthorised review, use, alteration, disclosure or distribution of this email (including any attachments) by an unintended recipient is prohibited. If you have received this email in error, please notify the sender by return email and destroy all copies of the original message. Any confidential or legal professional privilege is not waived or lost by any mistaken delivery of the email. Energy Queensland Limited accepts no responsibility for the content of any email which is sent by an employee which is of a personal nature.

Sender Details:

Energy Queensland Limited

Level 6, 420 Flinders Street Townsville QLD 4810

Energy Queensland Limited policy is to not send unsolicited electronic messages. Suspected breaches of this policy can be reported by replying to this message including the original message and the word "UNSUBSCRIBE" in the subject.
